

R.C.H. Public School

Tribheria, Siwan

Certificate – Safe Drinking Water

District Level Laboratory - PHED, Siwan,
Chemical Examination Report of Drinking Water Samples
 Sample collected on Spot by R.C.H. PUBLIC School & Received in the laboratory on Dated 28.05.2020

499

							PARAMETERS EXAMINED (Value in mg/l, except pH, otherwise mentioned)														
Sl. No.	District	Block	Gram Panchyat	Village	Name of nearest person/institution	pH	Turbidity	Conductivity	TDS	Total Hardness	Total Alkalinity	Calcium	Magnesium	Chloride	Sulphate	Iron	Nitrate	Fluoride	Arsenic	Remarks	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	
	SIWAN	BARHARIYA	BALAPUR	TINBHEDIYA	R.C.H. PUBLIC SCHOOL	7.10	1	-	225	180	190	32	-	15	BDL	0.24	BDL	BDL	-		
Min - Max Permissible Limit							6.5 - 8.5	5 NT	-	500 - 2000	200 - 600	-	75 - 200	30 - 100	250 - 1000	200 - 400	0.3 - 1.0	45	1-1.5	0.01	

Remarks : All Parameters are under Permissible Limit. Fit for drinking.
 BDL :- Below Detection Limit

Signature of the Chemist P.H. Division

Siwan

CHEMIST
 PUBLIC HEALTH ENGINEERING DEPARTMENT
 SIWAN

[Signature]
 08/06/2020

PRINCIPAL
 R.C.H. PUBLIC SCHOOL
 TRIBHARIYA